

EPA's Risk & Resiliency Assessments and Emergency Response Plans

Kelsey Waidhas

Metropolitan North Georgia Water Planning District

August 2019



Utility Sizing

- >100,000 people: large
- 50,000 - 99,999: medium
- 3,300 - 49,999: small

*wholesale purchasers certify based on population served

**wholesale & retail sellers certify based on combined total served population

| DOCUMENT | LARGE | MEDIUM | SMALL |
|--|--------------------|-------------------|-------------------|
| Risk & Resilience Assessment | March 31, 2020 | December 31, 2020 | June 30, 2021 |
| Emergency Response Plan | September 20, 2020 | June 30, 2021 | December 30, 2021 |
| Risk & Resilience Assessment #2 | March 31, 2025 | December 31, 2025 | June 30, 3026 |
| Emergency Response Plan #2 | September 20, 2025 | June 30, 2026 | December 30, 2026 |



Risk & Resiliency Assessment

- Risk from malevolent acts & natural hazards
- Resilience of source water, conveyance, barrier, collection/intake, treatment, storage, distribution, automated, electronic infrastructure
- Other O&M: How do you monitor? How do you budget/fund? How do you store & use chemicals? How do you evaluate needs?



Emergency Response Plan

- 6 months after the Risk & Resiliency Assessment:
- Use assessment conclusions for emergency response strategies, plans, procedures, etc.
 - Hazard detection/monitoring
 - Impact minimization/mitigation



Resources

American Water Works Association

1. [J100: Risk & Resilience Management of Water & Wastewater Systems](#)
2. [Cybersecurity Guidance & Tool](#)
3. [M19: Emergency Planning for Water & Wastewater Utilities](#)
4. [G440: Emergency Preparedness Practices](#)
5. [Utility Risk & Resilience Certificate Program](#)



Resources

EPA

1. [Vulnerability Self-Assessment Tool \(VSAT\)](#)
2. [Baseline Info on Malevolent Acts for Community Water Systems](#)
3. [Emergency Response Plan Template & Instructions](#)
4. [Creating Resilient Water Utilities](#)



Other Resources

- Metro Water District
 - Utility Climate Resiliency Study
- GEFA
 - Water System Interconnection, Redundancy and Reliability Act
Emergency Supply Plan
- National Association of Counties + Multi-State Information Sharing and Analysis Center
 - Membership + Cybersecurity Program



Submitting

- EPA'S ELECTRONIC PORTAL
 - Email/mail if necessary

| DOCUMENT | LARGE | MEDIUM | SMALL |
|--|--------------------|-------------------|-------------------|
| Risk & Resilience Assessment | March 31, 2020 | December 31, 2020 | June 30, 2021 |
| Emergency Response Plan | September 20, 2020 | June 30, 2021 | December 30, 2021 |
| Risk & Resilience Assessment #2 | March 31, 2025 | December 31, 2025 | June 30, 3026 |
| Emergency Response Plan #2 | September 20, 2025 | June 30, 2026 | December 30, 2026 |



Training

- Region 4: Friday, November 15, 9am-5pm
- Sam Nunn Atlanta Federal Center
61 Forsyth St SW
Atlanta, GA 30303
- Free for both in-person & webinar attendance



Announcements

Allie Orrego

Metropolitan North Georgia Water Planning District

August 21, 2019




Source Water Assessment Plan (SWAP) Update

- Update by January 1st, 2020
- Preliminary results-individual meetings:

September 16th-27th

Shellby Miller
smiller@atlantaregional.org



Considering AMI? Are you using AMI? Overwhelmed with data?

Join AMI Users group!

Bi-monthly conference calls

September 4th @1pm

– Discuss:

- Challenges
- Lessons learned
- questions to ask data
- Methods to analyze data

– Benefits:

- Knowledge base - community
- Improve customer experience
- Create confidence in methods
- Save time



Allie Orrego

E| aorrego@atlantaregional.org

P| (470) 378 1558



Residential Indoor Water Use: Comparing System Averages to New / Renovated Homes

Andrew D. Morris

Water Policy Officer

Metropolitan North Georgia Water Planning District

August 21, 2019

WS/WC TCC



WRF's 2016 Study on Residential End Uses of Water



Residential End Uses of Water,
Version 2

Report #4309b

PDF Report #4309b

Subject Area: Water Resources and Environmental Sustainability



Why is this study significant?

- Shows trends by following up on a similar 1999 study
- Used billing data from 23 utilities and 23,749 single-family homes (some from Cobb and Clayton)
- 95% confidence level that the samples were representative
- Sent 13,749 surveys sent, 4,643 returned
- Installed high-resolution flow data loggers at 763 homes across participating utilities



Indoor Water Use Average - 1999, 2016, High-Efficiency




Figure ES.6 Indoor average gallons per capita per day, REU1999, REU2016, High Efficiency Studies

Baseline Water Use - 2017 District Plan

Single Family GPCD Weighted Average = 53

Multifamily GPCD Weighted Average = 46

See Table 4-4 for your county's average



1999 Avg; 2016 Avg; & Codes/Standards




Figure ES.3 Indoor per capita water use - REU1999 and REU2016

Codes/Standards and Market Trends

| <u>Fixture</u> | <u>Codes / Standards</u> | <u>Market Trends</u> |
|------------------------|--------------------------|--|
| Toilet | 1.28 gpf | 1.1 gpf, 1.0 gpf, 0.8 gpf |
| Showerhead | 2.5 gpm | 2.0 gpm, 1.8 gpm, 1.5 gpm |
| Clothes Washer | 20 gallons per load | 14 gallons per load |
| Kitchen Faucet | 2.0 gpm | 1.8 gpm, 1.5 gpm |
| Lavatory Faucet | 1.5 gpm | 1.2 gpm |
| Leak Detection | None | Utility leak notices; behind the meter tech |

Estimating Indoor Use in New/Renovated Residential

- Indoor usage frequency and duration relatively stable across utilities (e.g. 5 toilet flushes per person per day; average shower is ~460 to 480 seconds)
- Indoor usage frequency and duration relatively stable in WRF REU 1999, REU 2016, and other studies
- WRF data is limited to single-family homes, but no reason to expect multifamily usage frequency and duration to vary significantly
- Dominant driver of total water use is plumbing fixture and appliance efficiency from home to home



WaterSense New Homes Tools for Estimating Water Use

Large lot



Large home

Small home



Small lot



So what is the gpcd indoor water use for new/renovated single and multifamily residences?

Step 1 - We are seeking utility partners who want to examine water use in new / substantially renovated single-family and multi-family developments in their service areas

Step 2 - District staff will use WRF and WaterSense data to estimate indoor water use in gpcd at the chosen developments

Step 3 - District and utility staff will use billing data and customer surveys to determine actual indoor water use in gpcd at the chosen developments

Step 4 - District and utility staff will document and present findings on actual indoor water in chosen developments and potential planning and design implications



Questions and Discussion



Like Us on Facebook

Metropolitan North Georgia Water Planning District



Follow us on Twitter

[@NorthGAWater](https://twitter.com/NorthGAWater)



Follow us on Instagram

[@NorthGAWater](https://www.instagram.com/NorthGAWater)

Andrew D. Morris
Water Policy Officer

amorris@northgeorgiawater.com

470.378.1549



Indoor Water Trends and Wastewater Infrastructure Implications

Danny Johnson

Manager

Metropolitan North Georgia Water Planning District

August 21, 2019

WW TCC



Indoor Water Use Average - 1999, 2016, High-Efficiency




Figure ES.6 Indoor average gallons per capita per day, REU1999, REU2016, High Efficiency Studies

Baseline Water Use - 2017 District Plan

Single Family GPCD Weighted Average = 53

Multifamily GPCD Weighted Average = 46

See Table 4-4 for your county's average



Codes/Standards and Market Trends

| <u>Fixture</u> | <u>Codes / Standards</u> | <u>Market Trends</u> |
|------------------------|--------------------------|--|
| Toilet | 1.28 gpf | 1.1 gpf, 1.0 gpf, 0.8 gpf |
| Showerhead | 2.5 gpm | 2.0 gpm, 1.8 gpm, 1.5 gpm |
| Clothes Washer | 20 gallons per load | 14 gallons per load |
| Kitchen Faucet | 2.0 gpm | 1.8 gpm, 1.5 gpm |
| Lavatory Faucet | 1.5 gpm | 1.2 gpm |
| Leak Detection | None | Utility leak notices; behind the meter tech |

So what impacts do these trends have on wastewater infrastructure ?

- Plant capacity
- Plant process control
- Sewer capacity
- Sewer flushing velocity
- Corrosion
- Pump station impacts
- Energy costs
- Others?

Theoretical Change in Concentration

| | District Plan Year | | | High Efficiency Home |
|---|--------------------|-------------|------------------|----------------------|
| | 2003 (1999) | 2009 (2006) | 2017 (2011-2014) | |
| Indoor gpcd | 70 | 69 | 53 | 36.7 |
| I&I (2003 held constant) | 14 | 14 | 14 | 14 |
| Estimated gpc Wastewater Generation | 84 | 83 | 67 | 50.7 |
| | | | | |
| Theoretical Change in Concentration of Equivalent Pollutant Load | 1 | 1.0 | 1.3 | 1.7 |



RESEARCH STUDIES



Effects of water conservation on sanitary sewers and wastewater treatment plants

DeZellar, Maier
1980



1975-1977 Northern California Drought

Surveyed the effect of conservation on wastewater quantity and quality during the 1975-1977 drought

Included 14 wastewater treatment plants of varying sizes (0.033 to 90.6 MGD)



General Findings

- Flow
 - 13 of the 14 plants experienced decreased flows between 15% and 61%
 - Three largest - 15% to 17%
 - Three smallest- 33% to 61%
- BOD
 - Concentrations generally increased between 25% and 40%
 - Three largest - 12% to 31%
 - Three smallest- 6% to 61%



General Findings

- Garbage disposals
 - Some saw per capita BOD and TSS reductions due to declining use of garbage disposals, which were not allowed by some communities' conservation plans
- Solids settling
 - Possible reduction in per capita loading at the treatment plant due to reduced velocity settling in pipelines
- Nitrogen, sulfur, and phosphate
 - Effects not precisely defined



General Findings

- Wastewater treatment processes modeled
 - Predict effluent benefits from longer residence time
 - Lower total operational costs due to hydraulic loading reductions but higher costs to treat 1,000 gal
- Additional costs related to increased odor control needs should be anticipated
- Other effects on unit processes discussed
- Recommendations included for future designs of collection systems and treatment trains



A mathematical model to plan for long-term effects of water conservation choices on dry weather wastewater flows and concentrations

Lauren M. Cook, Constantine Samara, Jeanne M. VanBriesen

Carnegie Mellon University
2018



Purpose of model

“The model could be used by wastewater utilities to understand how interacting influences (e.g. rate of conservation, growth or decline of population, system infiltration) could result in a benefit (deferring plant expansion) or challenge (risk of low flow conditions) to the wastewater system as a result of conservation practices.”







Fig. 1. Conceptual approach to modeling urban wastewater flows. External flows consist of industrial flow, infiltration, and inflow. Base sanitary flow consists of residential and commercial flow.



Upper Bound – Need for Expansion

Lower Bound – Critical Sedimentation/Corrosion Flows

Fig. 3. Dry weather flow for design and initial conditions (first group of bars) and for two time points: 2030 (second group of bars) and 2050 (third group). Projections shown for each conservation scenario. Threshold for plant expansion is represented as a black, dashed line. Risk level 2 (20% decrease) is shown as a brown, dotted line. (For interpretation of the references to colour in this figure legend, the reader is referred to the web version of this article.)




Fig. 4. Total dry weather flow over time under non-excessive infiltration with gradual conservation (thin lines) and moderate conservation (thick lines) for increasing population (top lines), stable population (middle lines), and decreasing population (bottom lines). Threshold for expansion represented as black, dashed line. Risk levels 1 to 4 shown as dotted, horizontal lines from top to bottom, respectively.



General Findings

- Reported the floor for indoor conservation in the US is 36.7 gpd per capita. However, this is likely not the floor based on market trends in efficiency in the United States. This is slightly higher than the 2011 level for indoor use in the Netherlands which is 34 gpcd.
- “The long-term effects of water conservation on wastewater collection and treatment systems are unknown.”
- Changes in concentration do occur as a result of conservation practices.



General Findings

- Systems with high levels of infiltration (~30% or more of total dry weather flow) will benefit the most from conservation practices since declines in per capita flow could delay the need for plant expansion or decrease the need for repairs due to I&I.
- Systems with low levels of infiltration (less than 5% of dry weather flow) are most at risk of negative effects from implementing conservation practices. These system may be at risk to settling or corrosion issues if the velocity falls below the level needed for self cleaning.
- Declines in per capita use lead to an increase in average dry weather pollutant concentrations; however increases are expected to be within the design tolerances of the wastewater plant (Metcalf & Eddy et al., 2003) as long as infiltration is not drastically increased or decreased.
- In example case, BOD5 and TSS influent concentrations never exceeded 600 and 700 mg/L and never fell below 200 mg/L.



General Findings

- Only systems with very large industrial flows (30% or more) should be concerned with declines in these flows due to conservation.
- Utilities should be less concerned about long-term changes in concentration as a result of conservation practices, and more concerned with impacts resulting from declines in flow [loss of flushing velocity].



Impact of water source management practices in residential areas on sewer networks - A review

Marleni, Sharma, Gray, Burn
Victoria University Melbourne
2012



General Findings

- Authors reviewed literature related to:
 - Water Demand Management
 - Greywater Recycling
 - Rainwater Harvesting
 - Sewer Mining
- Suggests that most of the source management practices will complicate odor, blockages, and corrosion in sewer systems, but rainwater harvesting might provide benefits to the system.



Takeaways

- Long term
 - Newly designed systems should consider sizing and loading implications from current plumbing code
 - Larger/older systems → Slow change → Easier to implement process and design changes over time
 - Smaller/newer systems → Review design assumptions and plan for operational changes
- Short term
 - Short term conservation strategies (e.g. required reductions) more likely to be disruptive



Potential for Further Study in the District

Comparison study of two or more sewersheds (new and old) to assess: flows, solids settling, water quality, corrosion indicators

Review of 2007-2008 drought response (10% reduction requirement, November 2007) and effect on influent and effluent data

Consider partnering with the Water Research Foundation or Alliance for Water Efficiency

Utility Partner(s) Needed

Other study needs?



Questions?



Like Us on Facebook

Metropolitan North Georgia Water Planning District



Follow us on Twitter

[@NorthGAWater](https://twitter.com/NorthGAWater)



Follow us on Instagram

[@NorthGAWater](https://www.instagram.com/NorthGAWater)

**Danny Johnson, PE
Manager**

djohnson@northgeorgiawater.com

470.378.1552



Biosolids Task Force Update

- GAWP Residuals Committee
- Data collection effort
 - EPA ECHO data
 - GOES application
 - What data are you submitting through digital reporting?
- Connecting with regulators and agricultural community
- NPDES form update - email address being added
 - May help with future surveys
- Other?

